

ASBESTOS LOCATIONS

BUILDING

BUILDING	ASBESTOS LOCATIONS							Comments
	Pipe Insulation	Pipe Joint/Elbow	Confirmed Floor Tile and/or Mastic	Possible Floor Tile	Sprayed On	Boiler Breeching	Misc	
CAMPUS								
Allyn Hall								
Bio Sci I & II						X		X-Sealant coating on ductwork
Brehm								
Campus Svcs								
Community Center								
Creative Arts								
Diggs Lab								
Fawcett Hall	X	X						X-Tunnel
Fine Arts/Svc Bldg								
Geology Support								
Hamilton Hall						X		X-Water Tank
Health Sciences						X		X-Bench Tops
Library								
Library Annex								
Math & Micro								
Med Sci						X		X- Valve Packing
Millet Hall	X	X					X	X-Millet/Oelman Tunnel. No other known in bldg.
Mini University								
Nutter Center								
Oelman Hall					X			X-Possible on I-Beam(s) in Elevator Shaft(s)
Rike Hall								
Rockafeld House								

	Pipe Insulation	Pipe Joint/Elbow	Confirmed Floor Tile and/or Mastic	Possible Floor Tile	Sprayed On	Boiler Breaching	Misc	NO KNOWN ASBESTOS	Comments
Russ Engineering									
Setzer Pavillion									
Student Union							X		X-Tank Ins.
Television Center		X							Suspect Material in004
Transp/Water Treatment Bldg									
University Hall									
White Hall									
OFF CAMPUS									
Cox Heart Institute									
Duke Ellis									
Kettering Center									
Lake Campus							X		X-Fallen sprayed on behind brick columns



Confirmed

Suspect

No known asbestos (If any suspicious material is found during any work, contact EHS for an evaluation)

X

See Comments